

Aquifer Thermal Energy Storage in Germany


Peter Seibt & Frank Kabus

Geothermie Neubrandenburg GmbH
www.gtn-online.de

Contents


- Demand / surplus scenarios
- Classification
- Aquifer thermal energy storage
 - Introduction
 - Site assessment
 - Geological conditions
 - Technical dimensioning
- Selected projects
 - Rostock-Brinckmanshöhe
 - Neubrandenburg
 - Reichstag building / Berlin (seat of the German Parliament)

Demand / surplus scenarios




Heating / solar heat

Demand / surplus scenarios



Cooling / ambient air

Demand / surplus scenarios



Heating / waste heat
from power generation


Classification

Underground thermal energy storage


**Borehole Heat Exchangers
(vertical, horizontal)**

**Aquifers
(groundwater-bearing beds)**


Caverns/ shafts



Introduction




winter operation



summer operation


Mode of functioning

Introduction



Other schemes of Ates - principle of alternate operation

Introduction



Scheme of an aquifer store – flow-through principle

Geological conditions

Principally, aquifers (groundwater-bearing beds) which are intended for thermal energy storage should come up to the following requirements:

- Max. depth of 1000 m:
At present, a depth of up to 200 m represents the most favourable variant for the installation of low-enthalpy stores in terms of cost.
- Covered (confined) groundwater-bearing bed:
On condition that adequate technological storage parameters are selected, even phreatic aquifers can be used according to most recent studies.

Geological conditions

- Max. effective reservoir thickness approx. 30 m:
If thicker, special production techniques would be required due to the horizontal propagation of the thermal front.
- Homogeneous aquifer structure:
Strong interstratification may result in a smaller coefficient of recovery.


Geological conditions

- Geometrical aquifer structure:
Major differences in level relative to the aquifer top may lead to problems when re-producing the fluid accumulating in the top sections.
- Low regional base flow or detailed knowledge on the regional groundwater flow parameters:
Appropriate siting of the wells can influence the propagation of the thermal front which is important for long-term operation.

Geological conditions

- Appropriate chemical composition of reservoir fluid (heat transfer medium) and matrix:
Changes of the state in the working section of the reservoir must not affect reinjection.
- Store installation out of groundwater catchment areas:
Interference and quality impairment must be avoided.

Geological conditions



Geological potentials
of aquifer thermal
energy storage

Site assessment

- Depending on the state of the geological knowledge, at least two exploratory wells should be drilled down on the site, followed by geophysical logging giving evidence on:
 - * depth and thickness of the aquifers
 - * existence of aquicludes in the under- and overlying sections of the aquifer intended for thermal energy storage
 - * non-homogeneities in the aquifer
- Pump and injection tests – duly recording the changes of the water level in the water and observation wells - are to determine the productivity and injectivity of the water well.

Site assessment

- Objectives of the laboratory analysis of matrix and fluid:
 - * Mineralogical investigations of the matrix to describe potential damages to the reservoir caused by precipitation or intrastratal solution caused by temperature changes
 - * Determination of the grain size distribution to characterise the reservoir

Site assessment

- * Geochemical investigation of the groundwater to identify the water components with regard to their reaction behaviour in changed temperature conditions
- * Determination of the actual microbiological state of the groundwater to identify the sensitivity of the reservoir to temperature increases

Site assessment


- * Isotope-hydrogeological analysis to determine the hold-up time of the groundwater and to derive a potential geohydraulic communication among neighbouring wells
- As the geometrical aquifer structure is especially important, shallow seismics proved to be an efficient method to enhance the state of hydrogeological knowledge

Technical dimensioning

Comparing	Water well	ATES well
Water temperature	constant	cold/warm
Injection	no	yes
Mode of operation	continuous throughout the year	seasonal
Flow	continuous	discontinuous
Direction of flow	one direction	two directions


Technical requirements on the wells

Technical dimensioning



Type 1

(down to a depth of approx. 400 m)



Type 2

(down to depths from approx. 400 to 1,000 m)

Technical dimensioning

- The most important parameter is the well diameter which depends on several criteria to be observed:
 - * laminar flow in order to prevent the precipitation of ochre and incrustations in the screen section
 - * non-overspeeding of the critical flow velocity against the screen


Technical requirements on the wells

Technical dimensioning

- the diameter required for installation of the submersible pump
- resistance of the equipment to thermal shocks and corrosion


Technical requirements on the wells

Technical dimensioning




Principle scheme of the surface storage loop (when charging)

Technical dimensioning



Principle scheme of the surface storage loop (when discharging)


ATES Rostock-Brinckmanshöhe




Design and present view



ATES Rostock-Brinckmanshöhe




summer



winter


Technical concept of solar energy storage

ATES Rostock-Brinckmanshöhe




Energy balance of heat production

ATES Rostock-Brinckmanshöhe



ATES Rostock-Brinckmanshöhe




Siting of the heat store wells


ATES Rostock-Brinckmanshöhe

- geological formation: Quaternary
- depth: 13 m - 27 m
- store temperature: 11 °C
- porosity: ~20 %
- permeability: 0.25- 0.5 μm^2
- number of wells: 2
- internal distance: 55 m
- production and injection
flowrate: 20 m³/h
- injection temperature: 50 °C
- charging heat: 234 MWh/a
- discharging heat: 222 MWh/a

ATES Rostock-Brinckmanshöhe




summer



winter

Technical concept of solar energy storage

ATES Rostock-Brinckmanshöhe



ATES Rostock-Brinckmanshöhe

Collector roofs during construction



External view of the warm well cellar

ATES Rostock-Brinckmanshöhe




Heat exchangers for charging and discharging (left) and heat pump (right)




Well head during construction

ATES Rostock-Brinckmanshöhe




Heat capacities, 23.08.2002

ATES Rostock-Brinckmanshöhe




Storage loop parameters, charging, 23.08.2002

ATES Rostock-Brinckmanshöhe




Storage loop parameters, discharging, 1.9.2002

ATES Rostock-Brinckmanshöhe




Storage loop parameters, discharging, 27.11.2002

ATES Rostock-Brinckmanshöhe




Parameters at the heat pump condenser, discharging, 27.11.2002

ATES Rostock-Brinckmanshöhe




Model area and grid, store section - red

ATES Rostock-Brinckmanshöhe




Simulated temperature distribution when charging at a depth of 17 m, early September 2000

ATES Rostock-Brinckmanshöhe




Calculated temperature, model layers and velocity arrows along the track of intersection

ATES Rostock-Brinckmanshöhe




Calculated (red) and measured (black) temperature behaviour at the measuring-lance M3 in 2000

ATES Rostock-Brinckmanshöhe




Calculated (red) and measured (black rhombs) discharging temperature, end of 2000 (days since 1st May)

ATES Rostock-Brinckmanshöhe




Dependency of the discharging temperature on the well site

ATES Rostock-Brinckmanshöhe




Monthly heat balance of the system (2002)

ATES Rostock-Brinckmanshöhe



Monthly heat balance of the ATES (2002)

ATES Rostock-Brinckmanshöhe




Heat balances in 2001 and 2002

ATES Rostock-Brinckmanshöhe

	2001	2002	2004
•Solar fraction	32 %	43 %	49 %
•ATES recovery factor	36.5 %	64.5 %	48,5 %
•COP of heat pump	4.1	4.3	4,5

Essential figures


ATES Rostock-Brinckmanshöhe



- Observation well
- Temperature measuring lances


Position of the wells,
the temperature measuring-lances and
direction of natural groundwater flow

ATES Rostock-Brinckmanshöhe



Temperature profiles at measuring-lance M2,
5 m downstream of the warm well

ATES Rostock-Brinckmanshöhe




Temperature profiles at measuring-lance M3,
5 m upstream of the warm well

Neubrandenburg aquifer heat store



Geothermal Heating Plant and low-temperature heating network (12 MW, 80°C / 45°C)




Gas and Steam Cogeneration Plant and high-temperature heating network (200 MW, 130°C / 60°C)




District heat supply networks of the Neubrandenburger Stadtwerke GmbH (Public Utilities)

Neubrandenburg aquifer heat store




Characteristics of the power demand of the town of Neubrandenburg

Neubrandenburg aquifer heat store




Characteristics of the heat demand of the town of Neubrandenburg

Neubrandenburg aquifer heat store



Effect of heat storage

Neubrandenburg aquifer heat store




well construction

Neubrandenburg aquifer heat store

- Production horizons: Hettangian and Upper Postera
- Depth: 1,105 m – 1,172 m
1,237 m – 1,271 m
- Flowrate: 200 m³/h
- Production temperature: 50 °C and 54 °C
- Mineralisation: 118 g/l and 133 g/l

Parameters of the geothermal resource

Neubrandenburg aquifer heat store




Behaviour of the temperature when discharging

Neubrandenburg aquifer heat store



Working on the well Gt N 4/86 in 2002

Neubrandenburg aquifer heat store



Balance of generation in the district heat supply network
„Rostock Street“

Neubrandenburg aquifer heat store



Installation of the submersible pump
in the well Gt N 4/86 in 2002

Neubrandenburg aquifer heat store



Gt N 4/86 well head

Neubrandenburg aquifer heat store



Gt N 4/86 well head

Neubrandenburg aquifer heat store




Heat exchanger for heat discharge

Neubrandenburg aquifer heat store




Coarse filtration of the thermal water at the cold well

Aquifer thermal energy stores in the Berlin Spree river curve (Parliament District)





Aquifer thermal energy stores in the Berlin Spree river curve (Parliament District)



Parliament buildings supplied by ATES

Aquifer thermal energy stores in the Berlin Spree river curve (Parliament District)




Drilling fields



Aquifer thermal energy stores in the Berlin Spree river curve (Parliament District)

Drilling of a heat store well

Aquifer thermal energy stores in the Berlin Spree river curve (Parliament District)



Geological cross-section

Aquifer thermal energy stores in the Berlin Spree river curve (Parliament District)

• Geological formation:	Hettangian
• Depth:	285 m- 315 m
• Store temperature:	19 °C
• Mineralisation:	29 g/l
• Porosity:	30.4 %
• Permeability:	2.8- 4.2 μm^2
• Number of wells:	2
• Internal distance:	400 m
• Production/injection flowrate:	100 m ³ /h
• Injection temperature:	70 °C

Heat store parameters

Aquifer thermal energy stores in the Berlin Spree river curve (Parliament District)

• Geological formation:	Quaternary
• Depth:	30 m- 60 m
• Store temperature:	10 °C
• Porosity:	~30 %
• Permeability:	$> 1 \mu\text{m}^2$
• Number of wells:	12 in 2 groups
• Internal distance:	400 m
• Production / injection flowrate:	300 m ³ /h
• Injection temperature:	
in winter	5 °C
in summer	28 °C

Cold store parameters

Aquifer thermal energy stores in the Berlin Spree river curve (Parliament District)



Installation of the twin pipes in a heat store well

Aquifer thermal energy stores in the Berlin Spree river curve (Parliament District)




Installation of a heat store well head




Heat store well chamber

Aquifer thermal energy stores in the Berlin Spree river curve (Parliament District)




Summer



Winter


Technical concept of the storage of waste heat arising from a cogeneration plant

Aquifer thermal energy stores in the Berlin Spree river curve (Parliament District)



Energetic benefit from a heat store


Aquifer thermal energy stores in the Berlin Spree river curve (Parliament District)



Heat store – parameters of heat charging

Aquifer thermal energy stores in the Berlin Spree river curve (Parliament District)

- Until autumn 2002: Charging only
- First regular annual cycle: Completed by discharging in winter 2002/2003




Charging the heat store: Annual curve

Numerical model of the heat store: Structure


Operational data:
Quantities and charging
temperature

- 3-dimensional Finite-Element model grid with 9 model layers from 100 m to 400 m below ground
- Flow and propagation of the heat front


Temperature distribution in the underground




Numerical model of the heat store: Validation



Aquifer thermal energy stores in the Berlin Spree river curve (Parliament District)




Summer



Winter


Technical concept of the storage of ambient cold

Aquifer thermal energy stores in the Berlin Spree river curve (Parliament District)



Borehole grid in the Spree river curve


Aquifer thermal energy stores in the Berlin Spree river curve (Parliament District)



Siting of the wells


- Cold store
- Heat store

Aquifer thermal energy stores in the Berlin Spree river curve (Parliament District)



Cold store, doublet KS5/KS6 – parameters in cooling operation


Aquifer thermal energy stores in the Berlin Spree river curve (Parliament District)




Cold store, doublet KS2/KS3 - parameters during regeneration

Numerical model of the heat store

Simulated temperature distribution, March 2003



Simulated cooling-down since March 2002



Aquifer thermal energy stores in the Berlin Spree river curve (Parliament District)



Cold store well head



Heat store well head

Aquifer thermal energy stores in the Berlin Spree river curve (Parliament District)



Surface loop of the cold store



Surface loop of the heat store

Aquifer thermal energy stores in the Berlin Spree river curve (Parliament District)




Filter in the cold store loop



Heat exchanger in the cold store loop

Aquifer thermal energy stores in the Berlin Spree river curve (Parliament District)



Arrangement of the technical units

Aquifer thermal energy stores in the Berlin Spree river curve (Parliament District)

